



Life Is On

CLIPSAL
by Schneider Electric

PLEASE NOTE


- The installation, maintenance and eventual replacement of these devices must only be carried out by a qualified electrician in accordance with the appropriate statutory regulations and codes of practice.
- This electrical equipment must not be repaired.
- All applicable local, regional and national regulations must be complied with during the installation, use, maintenance and replacement of these devices.
- These devices should not be installed if, when unpacking them, you observe that they are damaged.
- Clipsal cannot be held responsible in the event of noncompliance with the instructions in this document and in the documents to which it refers.
- The service instruction must be observed throughout the life time of these devices.

⚠ ⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Turn off all power supply to the distribution board before working on the accessory installation.
- Use a voltage tester with a suitable rated voltage in order to check that all active conductors are not energized.
- Carefully inspect the work area to check that no tools or objects could have been left inside the equipment.



Failure to follow these instructions will result in death or serious injury.




1 Package Contents

Note: Follow the orientation for unboxing and rotate package by 180°

Remove carton box




2 Parts Identification






Meter panel

Front side




Rear side




Note: Provision for three meter isolation link mounting, one meter isolation link supplied with product

3

Meter Isolation Link and L7 Neutral Link Fixation




1. Pull out the meter isolation link fuse carrier from the base portion




2. Remove the nut and pull out the meter panel

Meter panel front side




1

Meter panel rear side




2

Meter panel front side




1.2 Nm

3




3. Wiring connection to meter isolation link.


Meter panel rear side




1.2 Nm



1.2 Nm



4. Wiring connection to neutral link.




1.5 Nm

5. After wiring, push back the meter panel to its original position and tighten the nut.

Note:



= Mandatory step to be followed




6. Re-assemble the fuse carrier to the base portion




Neutral and Earth Connection

Neutral and earth terminal bar





4


Circuit Protection Device Installation




1. Remove fascia plate




2. Use grommets or conduits to seal off open knockouts properly for routing wires



3. Add DIN mounted protection device as required
Note: DIN is suitable for 21 module of 18 mm each




4. Reassemble fascia plate



Note:




= Mandatory step to be followed



5. Fill the unused space with pole filler provided in accessory bag


5

Cable Protection Slide and Lead Tie-off Point to Help Comply to AS/NZS 3012 for Temporary Installation



1. Pass the leads through cable protection slide at the bottom opening and tie off before plugging into socket outlet

Note: Fill unused space with pole filler



2. Ensure door is closed after installation


Note:

! = Mandatory step to be followed


Note: To suit temporary and permanent installation, follow local service and installation rules

6


Doorlock Instruction




1. Knockout the slot from the inside of door



2. Dismount the pre-assembled locking strap



3. Reverse the locking strap in same position and reassemble it with the screws



Note: Padlock not included

Clipsal by Schneider Electric (Australia) Pty Limited
33-37 Port Wakefield Road
Gepps Cross
South Australia 5094

Customer Care Centre
Tel: 1300 369 233
Email: customer care.au@se.com
Fax: 1300 369 288
www.clipsal.com

GDE59545-05

© 2025 Clipsal Australia Pty Ltd - All rights reserved.

The identified trademarks and copyrights are the property of Clipsal Australia Pty Ltd unless otherwise noted.

Life Is On

CLIPSAL
by Schneider Electric